



# Compliance Statement

## Screened Category 6 ISO/IEC, EN & TIA/EIA Communication Cable

**Draka Communications Identification P/N 1000786**

Category 6, Individual Foil and Overall Braid Screened  
100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Flame Retardant, LS0H, Copper Cable

**Draka Comteq UK, Ltd.  
Crowther Road, Washington  
Tyne and Wear, NE8 0AQ, England**

***Compliance Statement No. 109475A***

*This Screened ISO/IEC, EN & TIA/EIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of 2<sup>nd</sup> edition ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2007, ANSI/TIA Generic Cabling Standard 568-C.2 (modified to cover individual foil and braid screened cables), 2<sup>nd</sup> edition IEC Cable Standard 61156-5, and the requirements of CENELEC Cable Standard EN 50288-5-1. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 15<sup>th</sup> March 2010

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 15<sup>th</sup> March 2010

*Paul Villien*

Poul Villien  
Coordinating Manager