



We help ideas meet the real world



Compliance Statement

No. 2011-224

Connecting Hardware, Category 6

Company

Excel
Excel House
Junction Six Industrial Park
Electric Avenue
Birmingham B6 7JJ
United Kingdom

Product description

Excel Screened Category 6 RJ45 Toolless Keystone Jack characterised up to 250 MHz, 100 Ω

Product identification

100-210

Generic cabling and cabling components standards - Category 6 connector requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- IEC 60603-7-5:2010 (Ed. 2.0)
- EN 50173-1:2011
- EN 50173-2:2007 including amendment A1:2010
- ANSI/TIA-568-C.2:2009

Technical report

DELTA-N313026, DANAK-19J2567

EC Cabling product ID

5217

Certificate valid until

26 August 2012

This product has been tested by EC Cabling Group of DELTA and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The testing included measurement of NEXT with a compliant test plug and calculation of all the 14 test cases in both measurement directions. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis once a year.

Hørsholm, 26 August 2011

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable



TEST Reg. no. 19