



We help ideas meet the real world



# Compliance Statement

No. 2011-169

## Unscreened Channel, Class E

### Company

Excel  
Excel House  
Junction Six Industrial Park  
Electric Avenue  
Birmingham, B6 7JJ  
United Kingdom

### Channel Identification (4 connector model)

#### Horizontal Cable:

Excel 4 pair LSOH U/UTP cable, part code 100-071

#### Flexible Patch Cords:

Excel 4 pair LSOH U/UTP patch cords, part codes 100-310 1 meter, 100-312 3 metre

#### Wall Outlet:

Excel Keystone Jack, part code 100-011-BK

#### Patch Panel:

Excel Keystone Jack, for mounting in patch panel frame, part code 100-011-BK

### Generic cabling standards– Class E channel requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

### Technical report

DELTA-N312999-01, DANAK-19J2505

### EC Cabling Product ID

5140

### Certificate valid until

13 August 2012

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 13 July 2011

Erik Bech  
Test Manager

Claude Videt  
Project Manager

### DELTA

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. +45 72 19 40 00  
Fax +45 72 19 40 01  
[www.madebydelta.com/cable](http://www.madebydelta.com/cable)

